

自願性產品驗證證書

Certificate of the Voluntary Product Certification



證書號碼： V419041170380號A1

Certificate No.

茲據 士林電機股份有限公司(新豐廠) 申請自願性產品驗證，
經審查結果符合規定，准予並使用產品驗證標誌及識別號碼：
其登載事項如下：



The application made by SHIHLIN ELECTRIC & ENGINEERING for Voluntary Product Certification has been reviewed and found to be in compliance with related regulations. Therefore, registration is granted with the Certification Mark and the Identification

V41117 Details of the registration are as follows:

申請人： 士林電機股份有限公司(新豐廠)
Applicant

地址： 新竹縣新豐鄉中崙村234號
Address

生產廠場： 士林電機股份有限公司(新豐廠)
Factory

廠址： 新竹縣新豐鄉中崙村七鄰234號
Factory address

產品種類名稱： 大容量無熔線斷路器(限檢驗交流電壓600V以下，額定電流超過800A或短路
Type/name of product 容量超過220V/50kA、380V/30kA、440V/25kA及600V/20kA)

中文名稱： 無熔線斷路器
Chinese name

英文名稱： Molded Case Circuit Breaker
English name

型式： NF125-HT 3P 60Hz Ui:690V
Type 125AF(15/16/20/25/30/32/40/50/60/63/75/80/100/125A)
Icu/Ics:100/50kA(220V), 65/33kA(380V), 50/25kA(440V), 36/18kA(480V),
15/7.5kA(600V)

系列產品： 如附件
Series of type

驗證標準： CNS14816-2 (93年版)
Standards

標準檢驗局發證

This certificate shall be issued by the BSMI

本證書所載內容若有不符之處，以標準檢驗局系統登錄資料為主，查詢證書資料網址：

<https://civil.bsmi.gov.tw>

核可日期：中華民國	109	年	08	月	17	日
Registration date	2020	(year)	08	(month)	17	(day)
本證書有效期限至	112	年	08	月	16	日
Expiration Date	2023	(year)	08	(month)	16	(day)
發證日期：中華民國	110	年	06	月	17	日
Date of issue	2021	(year)	06	(month)	17	(day)



註：次年度自願性產品驗證年費繳納期限為當年11月30日，逾期未繳納者，經限期繳納屆期未繳納，即依自願性產品驗證實施辦法第21條第8款規定廢止產品驗證，並自次年度1月1日起生效。

自 願 性 產 品 驗 證 證 書

Certificate of the Voluntary Product Certification

證書號碼：V419041170380 號 A1

Certificate No.

型式： NF125-HT 2P 60Hz Ui:690V
es type 125AF(15/16/20/25/30/32/40/50/60/63/75/80/100/125A)
Icu/Ics:100/50kA(220V), 65/33kA(380V), 50/25kA(440V)

NF125-HT 4P 60Hz Ui:690V
125AF(15/16/20/25/30/32/40/50/60/63/75/80/100/125A)
Icu/Ics:100/50kA(220V), 65/33kA(380V), 50/25kA(440V), 36/18kA(480V),
15/7.5kA(600V)

(以下空白)

